



City of Austin

PUBLIC WORKS DEPARTMENT

Project Management Division

505 Barton Springs Road, Suite 900, Austin, TX 78704

Date: 10/3/18

PROJECT: Hornsby Bend Biosolids Management Plant Side Stream Treatment Plant Relief Project

CIP ID: 3164.048

IFB#: 6100 CLMC 713

SUBJECT: Answers to Bidders' Questions No. 2

The following are answers to Bidders' questions received on the above project. These answers do not modify the Bid Documents. Any modifications to the Bid Documents will be through an Addendum.

Q-1: How long of a warranty is required for the job and for equipment? Per the bid set specifications, there are multiple warranties identified:

- a. General conditions state warranty is 1 year.
- b. Aeration spec states warranty is 3 years.
- c. Submersible mixers warranty is 2 years.

A-1: **The contractor shall provide a 1 year written warranty as per Specification 00700, paragraph 13.7.1. The contractor shall also provide a manufacturers extended warranty if stated elsewhere in the technical specifications.**

Q-2: The following instruments appear to be existing on the drawing, however these instruments are shown to be provided on the appendix instrument list. Please clarify if we need to provide these instruments for this bid?

- a. (2) Mag Meter (FE/FIT-9101, FE/FIT-9102) on Dwg. 00N05
- b. (1) Hyacinth Complex High-High Level Switch on Dwg. 00N10

A-2: **a. See Drawing 02C01, Note 7.**
b. See Drawing 00N10

Q-3: Regarding The Spray Nozzles, Spec Section 15120, Page 2, Part 2.02, C, 1 States They Are To Be Leaded Bronze. However, Plan Sheet 126 Shows Them To Be Submerged At The Bottom Of The Scum Well. Should The Spray Nozzles Be Stainless Steel?

A-3: **See Drawing 08M02, Section D, Note 4 and Spec Section Spec Section 15120, Page 2, Part 2.02, C, 1.**